

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20160190, Building Permit - Commercial
Address: 1100 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Hood/Duct Inspection	John Borns	Partial	Friday, May 13, 2016

Partial Correction
1 Misc 1

GREASE DUCT LIGHT TEST:
VERTICAL STRAIGHT SECTION: OK TO INSTALL AFTER ONE HOLE
AT JOINT CORNER IS WELDED; **REMAINDER OF SHOP-WELDED
SECTIONS LIGHT-TESTED. HOLES DETECTED TO BE SPOT-WELDED
PRIOR TO INSTALLATION. THEN CALL FOR INSPECTION FOR ALL
FIELD WELDS TO BE LIGHT-TESTED.**

Comments: