

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRRES20152451, Building Permit - Residential  
Address: 417 SE MILL CREEK CIR, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mark Harding	Not Ready	Friday, May 13, 2016

### Corrective Action Required

1	Misc 1	-NAIL SIDING PER MANUFACTURER. RE NAIL ANY NAILS OVERDRIVEN 1/8TH INCH. -FIREBLOCK AND FIRESTOP THROUGHOUT, REAR WALL CHASE BOTH SIDES OF GREAT ROOM, FLUE CHASE LOOSE INSULATION NOT APPROVED, DEAD SPACE REAR OF FRIG BLOCK ENTIRE CHASE VERT. TO HORIZ. -ANCHOR GARAGE COLUMN WITH APPROVED ANCHOR, TAP CONS INCORRECT -FUR DOWN BASEMENT FOR GYP BOARD -INSTALL ADDITIONAL JOIST IN REAR BASEMENT WHERE JOIST SPACED 24" DO NOT INSULATE
---	--------	---

### Comments: