

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20160069, Building Permit - Commercial
Address: 1101 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	John Borns	Partial	Friday, May 13, 2016

Partial Correction
1 Misc 1

HARDENED AREA: OK TO POUR WHEN READY SECTIONS OF CONCRETE GRADE BEAM + INTEGRAL COLUMN FOOTINGS AS FOLLOWS: K/13.4 TO K/11.5 TO H.5/11.6; H.5/11.6 TO D.5/11.6; ON D.5 FROM 10.7 TO 13.5; D.5/13.5 TO D.5/14.2 TO SE CORNER + WEST TO COMPLETE PERIMETER AT K/13.4

Partial Correction
2 Misc 1

HARDENED AREA: OK TO POUR WHEN READY ISOLATED FOOTINGS: THREE F7; ONE F2;

Partial Correction
3 Misc 1

HARDENED AREA: FOOTING STEPS AT:
- ON D.5 FROM 10.7 TO 11.5
- TWO RUNS AT SE CORNER FROM (K) TO SOUTH
ENSURE MINIMUM 3" CLEARANCE BEFORE POUR. OK TO POUR WHEN READY.

Comments: