

CERTIFICATION

May 16, 2016

Re: Marble Slab Creamery / Great American Cookies
Summit Fair
Suite #L101, 1,600sf
880 Northwest Blue Parkway
Lee's Summit, MO 64086

To Whom It Concerns:

I, the undersigned Architect, am the Architect of Record for the above captioned project.

This letter is to certify that we have taken into consideration the heat gained from the Doyon cookie baking oven, along with all other heat gain sources in the space. The capacity of the existing ten ton roof-top unit is more than adequate to cool the 1,600sf space including all internal loads, the oven, all refrigeration equipment, appliances, customers and employees, outside air, transmission gains via roof and walls as well as solar gains via the glass storefront.

If there are any further concerns regarding this issue, please contact me at 404-584-1681.

Cordially,



Morton M. Gruber, AIA, Architect
Missouri Architectural Registration A-5720

