

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20151897, Building Permit - Commercial
Address: 1201 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Electrical Inspection - Commercial	John Borns	Partial	Tuesday, May 17, 2016

Partial Correction

1 Misc 1

OK TO COVER WHEN READY UNDER-SLAB ELECTRICAL CONDUIT & BOXES MATERIAL & WORKMANSHIP: **FROM (10) TO WEST B/L;**

G.C. AND E.C. TO ENSURE LAYOUT IS CORRECT.

Underslab Plumbing Inspection - Commercial	John Borns	Partial	Tuesday, May 17, 2016
---	------------	---------	-----------------------

Partial Correction

1 Misc 1

OK TO COVER WHEN READY UNDER-SLAB PVC SANITARY DRAIN, WASTE, & VENT PIPING: 6" PVC MAIN BUILDING DRAIN TO OUTSIDE BUILDING LINE + 4" STUB-UPS; **UPPER LIFT FROM (10) TO WEST B/L;**

NOTE IPC 312 / IRC P2503.5.1 REQUIREMENT FOR PRESSURE-TESTING PIPING SYSTEM.

Comments: