



---

## PLANNING AND DEVELOPMENT

### Fireworks Sales Permit - Special Event Applicant's Letter

**Date:** Tuesday, May 17, 2016

**To:**

**Applicant:** SKY BLOOMS FIREWORKS LLC Email: SKYBLOOMSFIREWORKS@GMAIL.COM

Fax #: <NO FAX NUMBER>

**Property Owner:** CP DEER BROOK PLAZA LLC Email:

Fax #: <NO FAX NUMBER>

**Applicant:** DEVELOPING POTENTIAL INC Email:

Fax #: <NO FAX NUMBER>

**From:** Hector Soto, Planner

**Re:**

**Application Number:** PRFW20160833

**Location:** 1125 NE RICE RD, LEES SUMMIT, MO 64086;

**Application Status:**

**Revisions Required:** See comments below and on attached sheet to determine corrections needed. Submit five (5) copies of revised drawings to the Department of Planning and Development. Revised plans will be reviewed within five (5) business days of resubmittal.

---

**Required Corrections / Conditions of Approval:**

<b>Building Codes Review (FW)</b>	Mike Copeland (816) 969-1204	Manager of Building Inspections Mike.Copeland@cityofls.net	Pending
-----------------------------------	---------------------------------	---	---------

<b>Fire Codes Review (FW)</b>	Jim Eden (816) 969-1303	Assistant Chief Jim.Eden@cityofls.net	Approved with Conditions
-------------------------------	----------------------------	--	--------------------------

1. The setup of the tent and retail seasonal sale of fireworks shall comply with current Missouri Revised Statutes-Fireworks Regulations and City of Lee's Summit Code of Ordinances. It is the responsibility of tent vendors and operators to become familiar and know the law as outlined in the Missouri Department of Fire Safety- Missouri Fireworks Regulations (May 20, 2013), and local ordinance.

2. Prior to stocking the tent with product, the tent must be inspected by the City of Lee's Summit Fire and Planning and Development Departments. After stocking, the tent is not allowed to open to the public until the stock of the tent is inspected by the fire department. Inspections may be scheduled by calling (816) 969-1300. All inspections are to be completed between 8 a.m. -5 p.m., Monday through Friday.

3. Fireworks shall not be stored, kept, or sold within fifty feet (50') of any gasoline pump, gasoline filling station, gasoline bulk station, or any building in which gasoline or volatile liquids are sold in quantities in excess of one (1) g a l o n e .

Ensure when the tent is set, it meets this requirement.

**Planning Review (FW)**

Hector Soto  
(816) 969-1604

Planner  
Hector.Soto@cityofls.net

Corrections

---

1. Provide a detailed sign plan for all signage proposed to be used at the site for review. All licensees must display at the stand location a 32 square foot banner which recites the identity of the licensee. This banner must be attached between two poles securely placed in the ground. All licensees must also display near the cash register (or other place of checkout) a sign of at least 12" x 12" which recites the identity of the licensee. As a condition of approval of the license application, all licensees must immediately remove any sign after being informed by City staff that the sign violates the licensee's approved sign plan.