

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20160190, Building Permit - Commercial
Address: 1100 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Hood/Duct Inspection	John Borns	Partial	Wednesday, May 18, 2016

Partial Correction

1 Misc 1

GREASE DUCT LIGHT TEST: SEAMS AND JOINTS LIGHT-TESTED. OK FOR 1ST LAYER FIRE-WRAP. THEN CALL TO REQUEST INSPECTION.

Corrective Action Required

3 Misc 1

IMC 507.16 COMMERCIAL KITCHEN GREASE HOOD
PERFORMANCE TEST: NEBB-CERTIFIED REPORT REQUIRED TO BE SUBMITTED TO INSPECTOR WHEN EQUIPMENT IS OPERATIONAL AND BEFORE COMMERCIAL USE. SMOKE CAPTURE TEST TO BE CERTIFIED BY 3RD PARTY OR WITNESSED BY INSPECTOR BEFORE ANY USE IS APPROVED.

Comments: