

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20151850, Building Permit - Residential

Address: 618 NW WILLOW DR, Unit:B, LEES SUMMIT, MO 64081618 NW WILLOW DR, Unit:C, LEES SUMMIT, MO 64081618 NW WILLOW DR, Unit:A, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	John Borns	Failed	Wednesday, May 18, 2016

Corrective Action Required

1	Misc 1	UNITS A & C: FINISH LANDSCAPING NOT READY FOR INSPECTION. ALL EXTERIOR YET TO BE INSPECTED.
---	--------	---

Corrective Action Required

2	Misc 1	UNITS A & C: IRC R703.1: OPENINGS AT EXTERIOR WALLS: SEAL HOLES, PENETRATIONS, ANNULAR SPACES IN EXTERIOR WALL (PIPE, CONDUIT, CABLES...)
---	--------	---

Corrective Action Required

3	Misc 1	UNITS A & C: MICROWAVE RECEPTACLES AT KITCHEN COUNTER AND LESS THAN 6' FROM EDGES OF SINKS NOT GFCI-PROTECTED.
---	--------	--

Corrective Action Required

4	Misc 1	UNITS A & C: UNIT "A" NE BR -- TWO ELECT RECEPES NOT SCREWED TIGHT TO BOXES
---	--------	---

Comments: