

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20160269, Building Permit - Commercial  
Address: 880 NW BLUE PKWY, Unit:J, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

|                                     |            |          |                        |
|-------------------------------------|------------|----------|------------------------|
| Inspection:                         | Inspector: | Outcome: | Date:                  |
| <b>Miscellaneous<br/>Inspection</b> | John Borns | Passed   | Thursday, May 19, 2016 |

**Comments: PARTIAL FINAL ON COOLER (2 COMPARTMENT) -- NO ISSUES FOUND. IF SPRINKLER LINES & HEADS ARE HOOKED-UP AND ACTIVE COOLER IS OK TO STOCK PRODUCT.**