

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFR20152896, Public Works Infrastructure Permit - Residential Trails of Parks Ridge 2nd

Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:
Inspection:

Inspector:

Outcome:

Date:

PW-Sanitary Sewer

Tom Chandler

Partial

Thursday,

May 19, 2016

Comments: Tie-in to existing MH 09-163 and istall 8" SDR 26 to MH 2-B1