

CODES ADMINISTRATION

Temporary Certificate of Occupancy

Permit #: PRRES20151850

Address: 618 NW WILLOW DR, Unit:C, LEES SUMMIT, MO 64081618 NW WILLOW DR, Unit:B, LEES SUMMIT, MO 64081618 NW WILLOW DR, Unit:A, LEES SUMMIT, MO 64081

Inspected On: Friday, May 20, 2016

Inspected By: John Borns

Expiration Date: 6/9/2016 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection -John Borns Temporary C of O Friday, May 20,

Codes Residential 2016

Corrective Action Required:

1 Misc 1 UNITS A & C: FINISH LANDSCAPING NOT READY FOR INSPECTION.

> ALL EXTERIOR YET TO BE INSPECTED. KEEP SILT/MUD OFF STREET AND AWAY FROM STORM INLETS PENDING SODDING OF LOT.

Corrective Action Required:

Misc 1 UNITS A & C: IRC R703.1: OPENINGS AT EXTERIOR WALLS: SEAL

HOLES, PENETRATIONS, ANNULAR SPACES IN EXTERIOR WALL (PIPE,

CONDUIT, CABLES...)