

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20151735, Building Permit - Commercial  
Address: 2100 SE BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	Mike Copeland	Passed	Friday, May 20, 2016
<b>Underslab Plumbing Inspection - Commercial</b>	Mike Copeland	Passed	Friday, May 20, 2016

**Corrective Action Required**

1	Misc 1	-NO CLEANOUTS FOR FIXTURES INSTALLED
---	--------	--------------------------------------

**Comments:**