

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20160873, Building Permit - Commercial  
Address: 3381 NW CHIPMAN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection - Commercial</b>	John Borns	Partial	Monday, May 23, 2016

Partial Correction  
1 Misc 1

OK TO COVER WHEN READY UNDER-SLAB PVC SANITARY DRAIN, WASTE, & VENT PIPING: MAIN BUILDING DRAIN FROM A.9/6.5 TO D.2/6.5; BRANCH ON (C) TO C.O. OUTSIDE WEST B/L; MAIN BLDG DRAIN EXTENDED SOUTH TO UNDER GRADE BEAM @ N/8.2; 4" BRANCH ON B.9 FROM MAIN BLDG DRAIN EAST TO 1.6; **LATERALS TO AND PIPING AT 103, 104, 127, 152, 153;**

NOTE IPC 312 / IRC P2503.5.1 REQUIREMENT FOR PRESSURE-TESTING PIPING SYSTEM.

<b>Underslab Electrical Inspection - Commercial</b>	John Borns	Partial	Monday, May 23, 2016
---	------------	---------	----------------------

Partial Correction  
1 Misc 1

OK TO COVER WHEN READY **ALL LOWER-LEVEL UNDER-SLAB CONDUIT NORTH OF (D);**

**Comments:**