

**PLANNING AND CODES ADMINISTRATION DEPARTMENT**  
**220 SE GREEN STREET**  
**LEE'S SUMMIT, MO 64063**  
**(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20160873, Building Permit - Commercial  
Address: 3381 NW CHIPMAN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection - Commercial</b>	John Borns	Partial	Wednesday, May 25, 2016

Partial Correction

1          Misc 1

OK TO COVER WHEN READY UNDER-SLAB PVC SANITARY DRAIN, WASTE, & VENT PIPING: MAIN BUILDING DRAIN FROM A.9/6.5 TO D.2/6.5; BRANCH ON (C) TO C.O. OUTSIDE WEST B/L; MAIN BLDG DRAIN EXTENDED SOUTH TO UNDER GRADE BEAM @ N/8.2; 4" BRANCH ON B.9 FROM MAIN BLDG DRAIN EAST TO 1.6; LATERALS TO AND PIPING AT 103, 104, 127, 152, 153; LATERAL TO AND PIPING AT RR 132; **LATERAL TO AND PIPING AT 139 AND 154, 155, 156;**

NOTE IPC 312 / IRC P2503.5.1 REQUIREMENT FOR PRESSURE-TESTING PIPING SYSTEM.

Partial Correction

2          Misc 1

OK TO COVER WHEN READY **ROOF DRAIN PIPING: TO BELOW GRADE AND UNDER GRADE BEAM AT [105];**

<b>Underslab Electrical Inspection - Commercial</b>	John Borns	Partial	Wednesday, May 25, 2016
-----------------------------------------------------	------------	---------	-------------------------

Partial Correction

1          Misc 1

OK TO COVER WHEN READY ALL LOWER-LEVEL UNDER-SLAB CONDUIT NORTH OF (D); EXTENSION OF 1-1/4" CONDUIT FROM (D) SW TO 152/153; **REMAINDER OF DEEP-TRENCHED CONDUIT SOUTH OF (E);**

**Comments:**