

Temporary Certificate of Occupancy

Permit #: PRRES20152404
Address: 3337 SW JESSIE CIR, LEES SUMMIT, MO 64082
Inspected On: Thursday, May 26, 2016
Inspected By: Mike Copeland
Expiration Date: 6/30/2016 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mike Copeland	Temporary C of O	Thursday, May 26, 2016

Corrective Action Required:

- | | | |
|---|--------|--|
| 1 | Misc 1 | -DECK STAIRS: INSTALL HANDRAIL, FLAT 2x6 TOO BIG, POUR DECK LANDING AT BOTTOM OF STAIRS, BLOCK RISORS ON STAIRS TO NOT ALLOW PASSAGE OF A 4" SPHERE.
-TWO OPEN BOXES UNFINISHED BASEMENT CEILING
-INSTALL FINAL GRADE, SOD, SPLASHBLOCKS
-RESTORE VEGETATION IN DISTURBED AREAS ON ADJOINING LOTS |
|---|--------|--|