

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20152552, Building Permit - Residential
Address: 1652 NE WOODLAND SHORES CIR, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Friday, May 27, 2016

Corrective Action Required

1	Misc 1	-DRIVEWAY NOT APPROVED ON RECORD -AC UNIT: INSTALL #10 WHIP CONDUCTORS; ID THE UNGROUND CONDUCTOR WITH PROPER COLOR -INSTALL COVER PLATE FOR THE GFCI BELOW DECK SEAL EXTERIOR WALL PENETRATIONS -INSTALL LOCK FOR OVEN BREAKER -VERIFY THAT THE BASEMENT SHOWER DOOR IS TEMPERED GLASS DOOR -PROTECT FURNACE CIRCUIT INSIDE A RACEWAY
---	--------	--

Comments: