

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20151744, Building Permit - Commercial  
Address: 2640 NE MCBAINE DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	Khanh Nguyen	Partial	Tuesday, May 31, 2016

Partial Correction

1 Misc 1

PERIMETER FOOTING OK, EXCEPT AT FOOTING JUMP LOCATIONS

Partial Correction

2 Misc 1

OK TO POUR WHEN READY TWELVE INTERIOR ISOLATED  
FOOTINGS

**Comments:**