

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20150016, Building Permit - Commercial  
Address: 518 NW MURRAY RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	John Borns	Passed	Wednesday, June 01, 2016

**Comments: OK TO POUR WHEN READY SPREAD FOOTING FOR TRASH ENCLOSURE. ENSURE MINIMUM 3" CLEARANCE FROM RE-BAR TO BOTTOMS AND BANKS. FOOTING NOT EXTENDED ACROSS GATE OPENING DUE TO EXISTING UTILITIES -- NOT CONSIDERED AN ISSUE.**