

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20160873, Building Permit - Commercial  
Address: 3381 NW CHIPMAN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Electrical Inspection - Commercial</b>	John Borns	Partial	Thursday, June 02, 2016
Partial Correction 1       Misc 1		OK TO COVER WHEN READY ALL LOWER-LEVEL UNDER-SLAB CONDUIT NORTH OF (D); EXTENSION OF 1-1/4" CONDUIT FROM (D) SW TO 152/153; REMAINDER OF DEEP-TRENCHED PVC CONDUIT SOUTH OF (E);	
Partial Correction 2       Misc 1		<b>OK TO COVER WHEN READY UNDER-SLAB RIGID STEEL AV CONDUIT THROUGHOUT EXCEPT APPROX 90LF OF THREE 2" PIPES PRESENTLY BEING TRENCHED NORTH OF (D);</b>	
<b>Underground Electrical Inspection - Commercial</b>	John Borns	Partial	Thursday, June 02, 2016
Partial Correction 1       Misc 1		<b>FOUR 3" PVC CONDUITS FOR BUILDING SERVICE FROM TRANSFORMER LOCATION: TO APPROX 12' SOUTH;</b>	
Partial Correction 2       Misc 1		<b>FOUR 3" PVC CONDUITS FOR FUTURE AND ONE 2" FOR TEMPORARY POWER FROM TRANSFORMER LOCATION: TO APPROX 10' WEST;</b>	

**Comments:**