

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20160249, Building Permit - Commercial
Address: 2321 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Khanh Nguyen	Failed	Friday, June 03, 2016

Corrective Action Required

1	Misc 1	-PROVIDE MIN. 18" BURIAL DEPTH FOR THE TWO UNDERGROUND CONDUITS
---	--------	---

Comments: