

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20160873, Building Permit - Commercial
Address: 3381 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Electrical Inspection - Commercial	Khanh Nguyen	Partial	Friday, June 03, 2016
 Partial Correction			
1 Misc 1		OK TO COVER WHEN READY ALL LOWER-LEVEL UNDER-SLAB CONDUIT NORTH OF (D); EXTENSION OF 1-1/4" CONDUIT FROM (D) SW TO 152/153; REMAINDER OF DEEP-TRENCHED PVC CONDUIT SOUTH OF (E);	
 Partial Correction			
2 Misc 1		OK TO COVER WHEN READY UNDER-SLAB RIGID STEEL AV CONDUIT THROUGHOUT EXCEPT APPROX 90LF OF THREE 2" PIPES PRESENTLY BEING TRENCHED NORTH OF (D); -INSPECTED THE REMAINING AV RMC TO EQUIPMENT RM	
 Underground Electrical Inspection - Commercial			
	Khanh Nguyen	Partial	Friday, June 03, 2016
 Partial Correction			
1 Misc 1		FOUR 3" PVC CONDUITS FOR BUILDING SERVICE FROM TRANSFORMER LOCATION: TO APPROX 12' SOUTH; -SERVICE CONDUCTORS RACEWAYS FROM TRANSFORMER PAD TO KCPL CT CABINET	
 Partial Correction			
2 Misc 1		FOUR 3" PVC CONDUITS FOR FUTURE AND ONE 2" FOR TEMPORARY POWER FROM TRANSFORMER LOCATION: TO APPROX 10' WEST;	

Comments: