

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161276, Building Permit - Commercial
Address: 506 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Commercial	John Borns	Passed	Monday, June 06, 2016

Comments: OK TO POUR PIERS WHEN READY. ENSURE 3" MINIMUM RE-BAR COVERAGE AT BOTTOMS AND BANKS.