

Temporary Certificate of Occupancy

Permit #: PRCOM20160269
Address: 880 NW BLUE PKWY, Unit:J, LEES SUMMIT, MO 64086
Inspected On: Thursday, June 09, 2016
Inspected By: John BornsMichael Weissenbach
Expiration Date: 6/16/2016 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Temporary C of O	Thursday, June 09, 2016

Corrective Action Required:

1 Misc 1 RESOLVE FIRE DEPT ISSUE(S)

Corrective Action Required:

2 Misc 1 NEC 408.4: LABELING OF ELECTRICAL CIRCUIT POSITIONS AT PANEL(S): EACH BREAKER POSITION MUST BE LABELED. MUST BE LEGIBLE, SPECIFIC. IF PANEL SCHEDULE IS USED NUMBER POSITIONS ON PANEL FRONT PER SCHEDULE. NO DITTO MARKS OR CONTINUATION SYMBOLS EXCEPT @ MULTIPLE POLE BREAKERS. LABEL UNUSED BREAKERS "SPARE". LABEL UNOCCUPIED POSITIONS "SPACE".

Alarm Test	Michael Weissenbach	Passed	Thursday, June 09, 2016
-------------------	------------------------	--------	----------------------------

