

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20152868, Building Permit - Residential
Address: 2613 SW 11TH ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Residential	Mark Harding	Passed	Thursday, June 09, 2016

All Rough Inspection - Residential	Mark Harding	Failed	Thursday, June 09, 2016
---	--------------	--------	-------------------------

Corrective Action Required

1	Misc 1	-INSTALL PLUMBING PROTECTION PLATES AT TOP PLATE BSMT BATH. -VENT ALL BATH FANS -MISSING STUD BSMT BED WALL. OK TO INSULATE.
---	--------	---

Comments: