

Temporary Certificate of Occupancy

Permit #: PRRES20152552
Address: 1652 NE WOODLAND SHORES CIR, LEES SUMMIT, MO 64086
Inspected On: Thursday, June 09, 2016
Inspected By: Khanh Nguyen
Expiration Date: 7/8/2016 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Temporary C of O	Thursday, June 09, 2016

Corrective Action Required:

- | | | |
|---|--------|---|
| 1 | Misc 1 | -AC UNIT: INSTALL #10 WHIP CONDUCTORS; ID THE UNGROUNDED CONDUCTOR WITH PROPER COLOR
**MAKE SURE THAT THE WHIP CONDUCTORS ARE RATED FOR WET LOCATION AS REQUIRED BY CODE

-INSTALL COVER PLATE FOR THE GFCI BELOW DECK |
|---|--------|---|