

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20160190, Building Permit - Commercial
Address: 1100 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Alternate Protection Systems Inspection	Michael Weissenbach	Passed	Thursday, June 09, 2016
Occupancy Inspection - Fire	Michael Weissenbach	Passed	Thursday, June 09, 2016
Final Building Inspection - Commercial	John Borns	Failed	Thursday, June 09, 2016

Corrective Action Required

1	Misc 1	CHECK ALL ELECTRICAL PANEL LABELS, CIRCUIT POSITION NUMBERS, AND CIRCUIT BREAKER LABELS. UPDATE AND CORRECT TO PRODUCE CURRENT, ACCURATE AND LEGIBLE LABELING.
---	--------	--

Corrective Action Required

2	Misc 1	ROOFTOP: - SUPPORT GAS PIPE AT 90'S AND TEE'S - ENSURE GAS PIPE IS STRAPPED AT ALL SUPPORT BLOCKS - ATTACH SLIP SHEETS TO PIPE SUPPORT BLOCKS - ELECTRICAL RECEPTACLES AT WET LOCATIONS MUST HAVE IN-USE COVERS
---	--------	---

Comments: GREASE HOOD VELOCITY TEST REPORT HAS BEEN RECEIVED AND IS BEING REVIEWED.