

# Temporary Certificate of Occupancy

---

**Permit #:** PRCOM20150016  
**Address:** 518 NW MURRAY RD, LEES SUMMIT, MO 64081  
**Inspected On:** Friday, June 10, 2016  
**Inspected By:** John Borns  
**Expiration Date:** 6/16/2016 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	John Borns	Temporary C of O	Friday, June 10, 2016

**Corrective Action Required:**

1 Misc 1 COMPLETE FINISH SITEWORK

**Corrective Action Required:**

2 Misc 1  
RESOLVE ANY PLANNING ISSUES  
RESOLVE ANY FIRE DEPT ISSUES  
RESOLVE ANY WATER DEPT ISSUES  
RESOLVE ANY PUBLIC WORKS DEPT ISSUES

**Corrective Action Required:**

3 Misc 1  
ROOFTOP:  
-HINGE KITS REQ'D ON GREASE EF'S  
-FINAL CLEAN ROOF SURFACE OF UNUSED MATERIAL AND DEBRIS

**Corrective Action Required:**

6 Misc 1 PROVIDE COPY OF ELEVATOR INSPECTION APPROVAL

**Corrective Action Required:**

7 Misc 1 COMPLIANT HANDRAILS REQUIRED AT EXTERIOR STAIR AT SW

Corrective Action Required:

8            Misc 1            COMPLIANT GUARDS AND HANDRAILS REQUIRED AT INTERIOR  
STAIR SW AND RAMP SW

Corrective Action Required:

9            Misc 1            BACKFLOW PROTECTION REQ'D AT ICEMAKER, COFFEE MAKERS,  
CARBONATED BEVERAGE FEED LINE, ETC -- TO BE VERIFIED

Corrective Action Required:

11          Misc 1            FIRESTOP HORIZONTAL CHASE AT ELEVATOR MACHINE ROOM

Corrective Action Required:

13          Misc 1            SEAL ALL EXTERIOR WALL OPENINGS

Corrective Action Required:

14          Misc 1            PLACE PERMANENT CIRCUIT SCHEDULES AT ELECTRICAL PANELS.  
DESIGNATE PANELS PER DRAWINGS.