

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20160190, Building Permit - Commercial  
Address: 1100 NE DOUGLAS ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Final Building Inspection - Commercial</b>	John Borns	Passed	Monday, June 13, 2016

**Comments: CHECK ALL ELECTRICAL PANEL LABELS, CIRCUIT POSITION NUMBERS, AND CIRCUIT BREAKER LABELS. UPDATE AND CORRECT TO PRODUCE CURRENT, ACCURATE AND LEGIBLE LABELING. AT ROOFTOP ONE CONDUIT SUPPORT BLOCK NEEDS SLIP SHEET TO PROTECT ROOF SURFACE. CONTINGENT ON COMPLETION OF PRECEEDING ISSUES, PERMIT SCOPE OF WORK IS OK FOR USE.**

**CLOSE PERMIT.**