

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20160069, Building Permit - Commercial
Address: 1101 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	John Borns	Partial	Monday, June 13, 2016

Partial Correction
4 Misc 1

OK TO POUR WHEN READY SECTIONS OF CONCRETE GRADE
BEAM + INTEGRAL COLUMN FOOTINGS AS FOLLOWS: **14/N TO
14/BB;**

**UFER GROUND CONNECTION ON LONGITUDINAL RE-BAR AT
CHILLER SCREEN WALL SE.**

Comments: