



LEE'S SUMMIT MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20161035	Date:	June 14, 2016
Project Title:	U.S. BEEF	Applicant:	
Location:	2321 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064	ALLIANCE FIRE PROTECTION LLC 130 W 9TH AVE STE 101 KANSAS CITY, MO 64116	
Type of Work:			
Occupancy Group:	B		
Description:	TENANT FINISH FOR OFFICE WAREHOUSE UNIT C	Primary: (913) 888-0647	
Construction Type:	Type IIB (Unprotected)		
Map Page:	175V		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Joe Dir

Released for Construction

1. 2012 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.

The existing sprinkler system riser shall be current with the required annual service/maintenance, with a current service tag on the riser.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.