

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20160494, Building Permit - Residential
Address: 266 SE COYLE DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mike Copeland	Failed	Friday, June 17, 2016

Corrective Action Required

1 Misc 1

-INSTALL 4 STUD SUPPORT FOR TRIPLE LVL ABOVE 1ST FL BED

-2ND FL FRONT BED GABLE WALL STUDS ARE NOT CONTINUOUS FROM FLOOR TO CEILING.

-ADD ANOTHER TIE DOWN DEVICE FOR GIRDER ABOVE 2ND FL FRONT BED BATH

-INSTALL SOLID 2X SUPPORT UNDERNEATH ALL POINT LOAD TO I BEAM IN BASEMENT

**OK TO INSULATE

Comments: