

Temporary Certificate of Occupancy

Permit #: PRCOM20151943
Address: 3680 NE AKIN DR, Unit:128, LEES SUMMIT, MO 64064
Inspected On: Friday, June 17, 2016
Inspected By: Khanh Nguyen
Expiration Date: 7/18/2016 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Khanh Nguyen	Passed	Friday, June 17, 2016
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Temporary C of O	Friday, June 17, 2016

Corrective Action Required:

1	Misc 1	-INSTALL FIRE EXTINGUISHERS PER IFC -RELABEL GAS SERVICE FOR UNIT 128 (FOR BOTH METERS SERVING THE 2 RTUs FOR UNIT 128)
---	--------	----------------------------------------------------------------------------------------------------------------------------