

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRRES20161425, Building Permit - Residential  
Address: 207 SW 3RD ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Final Mechanical Inspection - Residential</b>	John Borns	Partial	Friday, June 17, 2016

Corrective Action Required

1	Misc 1	NEC 110-22; 384-13; IRC E3606.2 LABELING OF ELECTRICAL CIRCUIT BREAKERS: AT ELECTRICAL SERVICE PANEL NO CIRCUIT BREAKER FOUND LABELED FOR A/C CONDENSER. INSTALLER TO IDENTIFY BREAKER FOR CONDENSER AND LABEL IT AT PANEL. NOTE MAXIMUM CIRCUIT AMPERAGE PER STICKER AT CONDENSER IS 30A. ELECTRICAL WHIP TO CONDENSER IS NOT SECURED TO BUILDING BUT IS DEEMED TO BE AN ALLOWABLE EXCEPTION DUE TO THE HOUSE CONFIGURATION.
---	--------	---

**Comments: INSTALLER PLEASE ADVISE JOHN BORNES WHEN BREAKER IS LABELED.**