

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20141072, Building Permit - Commercial
Address: 3301 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Mark Harding		Failed	Monday, June 20, 2016
Codes Commercial			

Corrective Action Required

1	Misc 1	Clubhouse- - provide Grippable handrails for stairs, provide 1 1/2" clearance on west handrail to landing.
		failed no change-6/20/16

Comments: