

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161035, Building Permit - Commercial
Address: 2321 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Khanh Nguyen	Failed	Wednesday, June 22, 2016

Corrective Action Required

1	Misc 1	-RELOCATE SPRINKLER HEAD -DEMO OUT WALL ABOVE RESTROOMS AREA; OR SUPPORT PER ENGINEER -SUPPORT MEZZENINE FLOOR ABOVE WALL OPENING
---	--------	---

Comments: