

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20160556, Building Permit - Commercial  
Address: 400 SE BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection - Commercial</b>	Mike Copeland	Partial	Wednesday, June 22, 2016

Partial Correction  
1          Misc 1

OK TO COVER WHEN READY UNDER-SLAB PVC SANITARY DRAIN  
PIPING AT: 3" PVC AT A153 FROM SCIENCE RM A154 TO ~33LF  
EAST\*\*; 4" PVC AT 156 CONNECTED TO EXSTG 6" @ N END;

ROOMS A154; A115; A119; A118; A121 APPROVED TO COVER

NOTE IPC 312 / IRC P2503.5.1 REQUIREMENT FOR  
PRESSURE-TESTING PIPING SYSTEM.

\*\*NOTE LESS LENGTH THAN SHOWN ON APPROVED DRAWINGS.

**Comments:**