

FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No: PRCOM20160873

Project Title: THE SUMMIT CHURCH -

FOUNDATION AND UNDERSLAB

Location:

3381 NW CHIPMAN RD, LEES

SUMMIT, MO 64081

Type of Work:

Occupancy Group: A-3

Description: FOUNDATION AND

UNDERSLAB FOR NEW CHURCH AND EDUCATION

FACILITY

BUILDING PERMIT: PRCOM20152438

Construction Type: Not Applicable

Map Page:

Date: June 24, 2016

Applicant:

ALPHA FIRE PROTECTION LLC 1510 W GEOSPACE DR

INDEPENDENCE, MO 64056

Primary: (816) 527-2260

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review Reviewed By: Joe Dir Released for Construction

- 3. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test. FIELD AND ACCEPTANCE TESTING WILL BE REQUIRED FOR THE SYSTEM PRIOR TO THE FINAL OCCUPANCY INSPECTION. TO SCHEDULE TESTING CONTACT THE FIRE DEPARTMENT AT 816-969-1300
- 2. PLANS SHOW AN ELECTRIC BELL ABOVE THE FDC. REPLACE THE ELECTRIC BELL WITH A OUTSIDE HORN/STOBE NOTIFICATION DEVICE TO ACTIVATE ON WATER FLOW ONLY. (VERIFIED AT INSPECTION)
- 1. FIRE DEPARTMENT CONNECTION SHALL BE LOCATED WITHIN 100' OF A FIRE HYDRANT. COORDINATE WITH THE PROJECT MANAGER TO CONFIRM LOCATION OF HYDRANTS TO BE INSTALLED.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.