

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20160494, Building Permit - Residential
Address: 266 SE COYLE DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mike Copeland	Failed	Tuesday, June 28, 2016

Corrective Action Required

1 Misc 1

-INSTALL 4 STUD SUPPORT FOR TRIPLE LVL ABOVE 1ST FL BED
EAST END*****STILL NOT DONE*****

-INSTALL SOLID 2X SUPPORT UNDERNEATH ALL POINT LOAD TO I
BEAM IN BASEMENT

***DREW ON SUB FLOOR WITH SHARPIE AN AAROW TO POINT
LOADS AND IN FIRST FLOOR EXTERIOR WALL WHERE 3 STUDS
INSTALLED INSTEAD OF 4*****

DO NOT ROCK

Comments: