

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20160568, Building Permit - Residential
Address: 425 SE MILL CREEK DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Residential	Mark Harding	Passed	Thursday, June 30, 2016
Gas Service Inspection - Residential	Mark Harding	Passed	Thursday, June 30, 2016
All Rough Inspection - Residential	Mark Harding	Failed	Thursday, June 30, 2016

Corrective Action Required

1	Misc 1	<ul style="list-style-type: none">- fire stop garage Chase, rear Chase great room, flu Chase,- support truss A2,3 1st floor- plumbing protection plates per code- security blocking- wall bracing- plumbing roof flashing.- no hurricane ties-laundry drain needs 2 pipe size diameters from trap to weir of drain.-support I joist, truss, wall, etc over front entry .- tie 2x6 front tall wall at 1st floor left of front door. Tie 2x6 tall wall at 2nd floor plate line where meets 2x4 walls.
---	--------	--

Comments: