

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20152404, Building Permit - Residential
Address: 3337 SW JESSIE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Mark Harding Codes Residential		Failed	Friday, July 01, 2016

Corrective Action Required

1	Misc 1	-DECK STAIRS: INSTALL HANDRAIL, FLAT 2x6 TOO BIG, POUR DECK LANDING AT BOTTOM OF STAIRS, BLOCK RISORS ON STAIRS TO NOT ALLOW PASSAGE OF A 4" SPHERE. -INSTALL FINAL GRADE, SOD, SPLASHBLOCKS -RESTORE VEGETATION IN DISTURBED AREAS ON ADJOINING LOTS
---	--------	---

Comments: