

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20160556, Building Permit - Commercial  
Address: 400 SE BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rough Electrical Inspection - Commercial</b>	Mark Harding	Partial	Tuesday, July 05, 2016

Corrective Action Required  
1 Misc 1

ROOMS-  
C30-EAST & WEST WALL  
C32-WEST & WEST WALL  
ELECTRCIAL AT CORNERS WILL TERMINATE ON FACE OF WALL.

**Comments:**