



FIRE DEPARTMENT

PLAN REVIEW CONDITIONS

July 07, 2016

LBP III LLC
3215 NE CARNEGIE DR STE 200
LEES SUMMIT, MO 64064

Permit No: PRCOM20161602
Project Title: ALLIED SERVICES
Project Address: 2706 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064
Parcel Number: 52240060300000000
Location: LAKEWOOD BUSINESS CENTER ON I-470 - PLAT P---LOT 16
Type of Work: CHANGE OF TENANT
Occupancy Group: BUSINESS
Description: TENANT BUILD OUT FOR OFFICE SPACE

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Joe Frogge

Pending

Fire Plan Review

Reviewed By: Joe Dir

Approved with Conditions

1. 2012 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building, each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

POST THE NUMERIC ADDRESS ON THE EXTERIOR OF ALL DOORS LEADING INTO THE SUITE. FRONT DOOR ADDRESSING SHALL BE READABLE FROM INDEPENDENCE AVE.
(VERIFIED AT INSPECTION)

2. 2012 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed. THE EXSITING FIRE SPRINKLER SYSTEM SHALL BE CURRENT WITH THE REQUIRED ANNUAL SERVICE / MAINTENANCE. A CURRENT SERVICE TAG SHALL BE POSTED ON THE RISER.
(VERIFIED AT INSPECTION)

3. 2012 IFC 906.2 - General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.
IF NOT EXISTING, SUPPLY 2A-10BC FIRE EXTINGUISHERS AS NEEDED. ONE FOR EVERY 3,000 SQ FT. (VERIFIED AT INSPECTION)

4. 2012 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions. HAVE CONTRACTOR PROVIDE SHOP DRAWINGS FOR ANY ALTERATIONS TO BE DONE TO THE FIRE ALARM SYSTEM

5. 2006 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation. HAVE CONTRACTOR PROVIDE SHOP DRAWINGS OF ANY ALTERATIONS TO BE DONE TO THE FIRE SPRINKLER SYSTEM.

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.