

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161543, Building Permit - Commercial
Address: 178 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Passed	Thursday, July 07, 2016

Comments: UNDERGROUND PVC CONDUIT AND 2 GROUND RODS IN PLACE. G.E.C. RUN TO GROUND ROD >6' N OF PEDESTAL. OK TO COVER WHEN READY.