

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20160496, Building Permit - Residential
Address: 3110 SE 3RD TER, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mike Copeland	Failed	Thursday, July 07, 2016

Corrective Action Required

1	Misc 1	-GARAGE PORTAL, SPLICE IN SHEATHING REQUIRES HORZ. BLOCK AND NAILED 3" OC. -FIRESTOP THROUGHOUT PER CODE. MAKE SURE INSULATION IS TIGHT IF USED AS FIRESTOPPING -VENT WATER HEATER (MAKE SURE UFFER IS ACCESSABLE AT FINAL) OKAY INSULATE
---	--------	---

Electrical Service Inspection - Residential	Mike Copeland	Passed	Thursday, July 07, 2016
--	---------------	--------	-------------------------

Comments: