

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20160069, Building Permit - Commercial
Address: 1101 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial		Partial	Monday, July 11, 2016
Partial Correction 1 Misc 1		OK TO POUR WHEN READY CONCRETE FOUNDATION WALL AND INTEGRAL COLUMNS/PILASTERS : K/13.7 TO K/11.6; K/11.6 TO 11.6/G; H.3/11.6 TO H.3/12.2 TO G/12.2 TO G/11.55; [K/13.7 TO J.9/EAST END; 13.8/J.9 & 14.9/J.9 TO 14.2/D.5* TO D.5/13.5; D.5/13.5 TO D.5/11.2; 11.55/G TO 11.55/D.5 TO COMPLETE PERIMETER WALLS; *INCLUDING #8 BARS AT TOP OF WALL PER ADDENDUM #4	
Partial Correction 2 Misc 1		ELEVATOR WALLS: E LINE BETWEEN 10.5 AND 11 LINE; 14 LINE BETWEEN K AND Q; BETWEEN 9.5 AND 9 AT S LINE	
Partial Correction 3 Misc 1		OK TO POUR WHEN READY C.I.P. CONCRETE COLUMNS @ I/11.5; I/12; I/13; H/13;	
Partial Correction 4 Misc 1		FOOTINGS AT HARDENED AREA COMPLETED & APPROVED FOR POUR. UFER GROUND CONNECTION ON LONGITUDINAL RE-BAR AT CHILLER SCREEN WALL SE.	
Partial Correction 5 Misc 1		OK TO POUR WHEN READY SECTIONS OF CONCRETE GRADE BEAM + INTEGRAL COLUMN FOOTINGS AS FOLLOWS: 14/N TO 14/Z; 14/Z TO DD/14 TO DD/12.3; DD/12.3 TO DD/9 TO 9/BB.5;	
Partial Correction 6 Misc 1		OK TO POUR WHEN READY ISOLATED FOOTINGS AT FOLLOWING	

LOCATIONS: 13/O; 13/S; 13/W; 13/Y; 13/AA; 12/W; 12/Y; 12/AA;
11/O; 11/S; 12/O; 12/S; CONNECTED PAIR W/10.5&11;
CONNECTED PAIR Y/10.5&11; 9/Y; 10/S; 10/W; 10/Y; 10/AA;
11/AA;

****OK TO POUR: ELEVATOR PAD AND F2 COLUMN PAD, F3
COLUMN PAD SOUTH OF ELEVATOR**

Partial Correction
7 Misc 1

STEP FOOTINGS RISING FROM HARDENED AREA FOOTING
ELEVATION: MIDDLE STEP @ 14/M TO COMPLETE STEPS ON 14;
SECOND STEP AT E/10.8;

Partial Correction
8 Misc 1

COLUMN PADS AT THE FOLLOWING LOCATIONS APPROVED TO
POUR PER DRAWINGS:
9.5/S; 9.5/T.5; 9/Y; 9/S; 9/O; 9/K; 9/I; 9/F; 7.6/Q; 7.6/U; 7.6/X;
6.7/O-G

FOOTING E LINE BETWEEN 10.5 AND 11 TO 6.7

Partial Correction
9 Misc 1

OK TO POUR WHEN READY: F6 @ I/11 + CONTIGUOUS F3 + TIE
BEAM FROM F6 TO PILASTER @ I/11.5

Partial Correction
10 Misc 1

**OK TO POUR WHEN READY: CONNECTED PAIR OF F7s @
K/10.25; F3 @ D/4 + CONTIGUOUS STRIP FOOTING; F3s AT G/4
AND J/4;**

Comments: