

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20160737, Building Permit - Commercial
Address: 403 SW WARD RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	Mark Harding	Passed	Tuesday, July 12, 2016

Rated Assembly Inspection	Mark Harding	Failed	Tuesday, July 12, 2016
----------------------------------	--------------	--------	------------------------

Corrective Action Required

1	Misc 1	-RATED WALL- INSTALLED 1" ROCK WITHOUT INSTALLING 1"X2" L STRIP ON FACE OF EXISTING WALL. CHANGE UL LISTING TO MATCH WHAT IS ON SITE OR REMOVE AND RECALL FOR "L" STRIP FRAMING INSPECTION. REVISE PLANS .
---	--------	---

Comments: