



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20161035	Date:	July 13, 2016
Project Title:	U.S. BEEF	Applicant:	
Location:	2321 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064	ATRONIC ALARMS INC 8220 MELROSE DR LENEXA, KS 66214	
Type of Work:			
Occupancy Group:	B		
Description:	TENANT FINISH FOR OFFICE WAREHOUSE UNIT C	Primary:	(913) 362-0000
Construction Type:	Type IIB (Unprotected)		
Map Page:	175V		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Joe Dir

Released for Construction

1. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test. ACCEPTANCE TESTING OF THE NEW INSTALLED ALARM DEVICES IS REQUIRED PRIOR TO THE FINAL OCCUPANCY INSPECTION. TO SCHEDULE A TEST CONTACT THE FIRE DEPARTMENT AT 816-969-1300

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.