



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No: PRCOM20152438
Project Title: THE SUMMIT CHURCH
Location:

3381 NW CHIPMAN RD, LEES
SUMMIT, MO 64081

Type of Work:

Occupancy Group: A-3

Description: NEW CHURCH WITH
ATTACHED EDUCATION
FACILITY

Date: July 13, 2016

Applicant:

ATRONIC ALARMS INC
8220 MELROSE DR
LENEXA, KS 66214

Primary: (913) 362-0000

FOUNDATION/UNDERSLAB PERMIT:

PRCOM20161873

Construction Type: Type IIB (Unprotected)

Map Page:

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Joe Dir

Released for Construction

1. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.
ACCEPTANCE TESTING OF THE FIRE ALARM SYSTEM WILL BE REQUIRED PRIOR TO THE FINAL OCCUPANCY INSPECTION. TO SCHEDULE TESTING CONTACT THE FIRE DEPARTMENT AT 816-969-1300

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.