

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20160556, Building Permit - Commercial
Address: 400 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Failed	Friday, July 15, 2016

Corrective Action Required

1	Misc 1	SPACES A118 & A121: - COMPLETE DRAIN PIPING AT A121 W WALL - REPAIR/REINFORCE DAMAGED STUDS @ A121 E - INSTALL BOCA PLATES TO PROTECT PVC PIPE - SOME ELECTRICAL BOX STAND-OFFS TOO SHORT - PROTECT COPPER DRAIN PIPE @ A121 W WITH SHIELD PLATES
---	--------	--

Comments: