

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161727, Building Permit - Commercial
Address: 522 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Electrical Inspection - Commercial	John Borns	Passed	Friday, July 15, 2016
Foundation Inspection - Commercial	John Borns	Passed	Friday, July 15, 2016

Comments: RE-BAR AND ELECTRICAL CONDUIT IN PLACE FOR POUR OF STEM WALL. FOOTING POURED WITHOUT INSPECTION. OK TO POUR STEM WALL WHEN READY. ENSURE INTERNALLY-LIGHTED SIGN IS LABELED PER NEC 600.3.